

ADDENDUM NUMBER: 2

To Contract Documents for:

Historic Whittier Railroad Plaza

Architect:
STANTEC
2515 A Street
Anchorage, AK 99503
Phone (907) 276-4245
Fax (907) 258-4653

October 3, 2014

This Addendum forms a part of the Contract Documents and modifies the original Bid Documents for the project.

Acknowledgment of receipt of this Addendum must be made on the proposal. This is a mandatory requirement and any bid received without acknowledgment of receipt of Addenda may be classified as non-responsive.

This addendum consists of the following:

Page(s) 2

BIDDER QUESTIONS OCTOBER 3, 2014

QUESTION 1

Concrete has quality control requirements for testing. Is there a 95% density requirement for the subgrade of the existing materials? If so, how many tests need to be taken?

RESPONSE to QUESTION 1

95% density is required for the subgrade. Perform testing and provide data from two (2) density tests on the compacted subgrade.

QUESTION 2

Six inches of "C-1" materials is specified on the plans on sheet L5.7. What is the specification for "C-1" material?

RESPONSE to QUESTION 2

References to "C-1" in the drawing set (Sheets L2.1-L5.7) should READ "D-1." Provide D-1 material as defined by Alaska DOT standard specification Grading D-1.

QUESTION 3

Are there any existing underground utilities on the site?

RESPONSE to QUESTION 3:

There are no other utility conflicts other than what is on the plans. It is the contractors' responsibility to call in for locates. Whittier is considered rural so plan on ten (10) working days lead time for utility locates.

QUESTION 4

The callouts on sheet L5.3 mention Additive Alternate #1 Footings and stone Veneer for Canopy Columns and Additive Alternate #2 Footer and Stone veneer for canopy columns. These descriptions seem to be different than those in the bid schedule. Is stone veneer for canopy columns to be included with Alt #1?

RESPONSE to QUESTION 4:

The above grade "Stone Veneer" called for on stair canopy columns is to be included in Bid Alternate #1. Note on Drawing L5.3 that calls out "Stair Canopy" as Add Alternate #2 should READ "Additive Alternate #1-Custom Canopy as manufacture by Polygon-Install per manufacturer's specifications."

END OF ADDENDUM NUMBER: 2